

Aberdeen Creek HOA Irrigation System Check

Date: 09/23/2020

Checked By: Cliff Reiss

Irrigation System Zones:

- **Zone 1 (Center Island)** – OK – no broken spray head or rotors
- **Zone 2 (West Beds)** – OK – no broken spray head or rotors
- **Zone 3 (East Grass)** – OK – no broken spray head or rotors
- **Zone 4 (West Grass)** – FIX– one broken rotor or line – Excelsior work order sent @9:30am
- **Zone 5 (East Beds/Front Island)** – OK – no broken spray head or rotors



➤

.....

Recommended Future Maintenance:

- Remove grass around heads – common area Zone 1 and sidewalk rotors
- Place rings around rotors in common area and sidewalk grass areas if needed
- Check for clogged spray heads and clean / replace
- Adjust coverage pattern on Rotors and spray heads
- Rewire PRO-C Controller for direct connection (instead of plug); install GFI outlet

System Details:

- PRO-C PCC-600 Controller operating OK
- Rain Sensor operating OK – set at ¼"